

中国强制性产品认证目录外确认书
Confirmation Letter for Outside the Scope
of China Compulsory Product Certification

Ref. No: CL- Seifert -260521-01

申请人: Applicant	Seifert Systems GmbH.	地址: Address	Address: Albert-Einstein-Str. 3 D-42477 Radevormwald, Germany
生产厂名称: Factory	Seifert Systems Ltd.	地址: Address	HF 09/10, Hal Far Industrial Estate, Birzebbuga, BBG3000, Malta
产品名称: Product Name:	Industrial control cabinets cooling units	型号: Model	KG- series, OC- series
产品标准: Standard	UL 484 / UL 60335-1, UL 60335-2-40	商标: Trademark	
		HS code:	8415821000

产品描述(包括使用场所) Product Description (utilization of product) :

The KG- and OC-series are air-air heat pump units/air conditioners intended as complementary accessories to large industrial equipment. This involves temperature stabilizing of electronic enclosures and electrical cabinets. These products are self-contained and are DC or AC single/three phase powered, less than 600V. All KG- and OC-series units are intended to be installed and maintained by technically competent and qualified persons only using only the supplied material and according to the supplied instructions.

Units have two completely separate air circuits which ensure that the clean cabinet air does not come into contact with the ambient air which may be dirty or polluted. Control cabinet air conditioners can dissipate large quantities of heat from sealed enclosures such into the ambient air whilst at the same time reducing the enclosure internal temperature to below that of the ambient air. These are fit for purpose within the rated ambient conditions (e.g. dusty and oily air or high air temperatures between 20°C and 60°C), and the declared allowable ingress from the environment.

KG 和 OC 系列是工业用空气-空气热泵机组/空调，用作大型工业设备的辅助配件。这涉及电子外壳和电气柜的温度稳定。这些产品是独立的，直流或交流单相/三相供电，小于 600V。所有 KG 和 OC 系列装置均应由技术合格的人员安装和维护，仅使用所提供的材料，并按照所提供的说明进行安装和维护。

机组有两个完全独立的空气回路，确保洁净的机柜空气不会接触到可能脏污或污染的环境空气。控制柜空调可以将大量热量从密封外壳散发到环境空气中，同时将外壳内部温度降低到低于环境空气的温度。这些设备适用于额定环境条件（例如，灰尘和油性空气或 20° C 和 60° C 之间的高温空气），以及声明的允许环境进入。

确认意见 Conclusion:

基于产品描述，如上工业用空气-空气热泵机组/空调不在目前的中国强制性产品认证目录内。

According to the product description, the industrial models above are out of scope of China Compulsory Product Certification currently.

本确认书的有效期至: 2027 年 5 月 20 日
Validity Period: May 20th of 2027

日期: 2026 年 5 月 21 日
Issue date: May 21st of 2026

本确认书给出的确认意见仅反映苏州 UL 美华认证有限公司对于相关文件的理解和意见。

苏州 UL 美华认证有限公司是独立于国家市场监督管理总局 (“SAMR”)、国家认证认可监督管理委员会 (“CNCA”) 和中国质量认证中心 (“CQC”) 的第三方机构。

国家市场监督管理总局有权对《强制性产品认证目录描述与界定表》进行最终解释。

This letter reflects the views and findings of UL-CCIC Company Limited. UL-CCIC Company Limited is an independent 3rd party organization, not directly associated with State Administration for Market Regulation (SAMR), Certification and Accreditation Administration of the People’s Republic of China (CNCA), nor China Quality Certification Center (CQC).

State Administration for Market Regulation is responsible for final explanation of Compulsory Product Certification Catalogue Description and Scope Definition.

产品明细 Product List:

KG-4266	KG-4304	KG-8403*	KG-8503*	KG-9503	KG-4650
KG-4267	KG-4305	KG-8405*	KG-8505*	KG-9506	KG-4675
KG-4268	KG-4308	KG-8406*	KG-8506*	KG-9508	KG-4533
KG-4269	KG-4309	KG-8408*	KG-8508*	KG-9510	KG-4534
KG-4270	KG-4310	KG-8412*	KG-8512*	KG-9512	KG-4535
KG-4271	KG-4315	KG-8420*	KG-8515*	KG-9515	KG-4555
KG-4272	KG-4320	KG-8425*	KG-8520*	KG-9520	KG-4480
KG-4274	KG-4325	KG-8440*	KG-8525*	KG-9525	KG-4481
KG-4295	KG-4330	KG-8462*	KG-8540*	KG-9530	KG-4482
	KG-4340		KG-8562*	KG-9540	KG-4484

* may be followed by RC

KG-4604	KG-/OC-8705	OC-5704	OC-4005	OC-4108	OC-4403
KG-4609	KG-/OC-8706	OC-5705	OC-4008	OC-4106	OC-4404
KG-4612	KG-/OC-8708	OC-5708	OC-4012	OC-4109	OC-4408
KG-4613	KG-/OC-8712	OC-5709	OC-4020	OC-4112	OC-4410
KG-4515	KG-/OC-8715	OC-5710	OC-4037	OC-4114	OC-4415
KG-4520	KG-/OC-8720	OC-5715	OC-4050	OC-4117	OC-4418
KG-8615	KG-/OC-8725	OC-5720	OC-4537	OC-4120	OC-4635
KG-8625	KG-/OC-8730	OC-5726	OC-4540	KG-4510	OC-4660
KG-8650	KG-/OC-8740	OC-5731	OC-4105	KG-4514	KG-4504
KG-/OC-8703	KG-/OC-8762	OC-5741	OC-4107	KG-4516	KG-4509

KG-9210	KG-4366	KG-4370	KG-9225
KG-9215	KG-4367	KG-4371	
KG-9225	KG-4368	KG-4372	
KG-9225	KG-4369	KG-4374	
SK9663			


Model numbers may be followed by yf


产品照片 Product Photo/铭牌 Nameplate:



SEIFERT

42477 Radevormwald | Germany
info@seifertsystems.com

SLIMLINE Neo	KG-9225 SK9663	
Schaltschrankkühlgerät		
Enclosure cooling unit		
Climatiseur p. armoire électrique		
Part no. / Bestell Nr.	92259663	
Voltage - Frequency	115-230 V ~ 50/60 Hz	
Spannung - Frequenz		
Max. input power	1,250 W	
Max. Nennleistung		
Input power L35L35	1,000 W	
Nennleistung L35L35		
Rated current L35L35	9.3 / 4.6 A	
Nennstrom L35L35		
Starting current / Anlaufstrom	5 / 2.5 A	
Max. current / Nennstrom	12 - 5.5 A	
Fuse rating	15 A (T)	
Vorsicherung MOP		
SCCR	5 kA	
Cooling capacity L35L35	2,300 W	
Nutzkühlleistung L35L35		
Enclosure heater / Schrankheizung		
BCSC	6.4 A	
Temp. range / Temp. Bereich	10°C - 50°C	
Refrigerant / Kältemittel	R 290 / 0.02	
Refrigerant charge / Füllmenge	99 g / 3.49 oz	
High / low pressure	30 / 7 bar	
Hoch / niedrig Druck	435 / 101 psig	
Weight / Gewicht	30 kg	
Ingress protection / IP Schutzklasse EN 60529		
Enclosure side / Schrankseite	IP 54	
Hermetically sealed / Hermetisch geschlossen		
Leakage tested / Dichtheit geprüft EN 378-1		



Production date / Produktionsdatum 0526



Serial No. X99990002




Made in Malta

附加说明 Additional Information:




本判断系基于国家市场监督管理总局 2023 年第 36 号公告-强制性产品认证目录描述与界定表 (2023 年修订)。

This decision is based on SAMR Circular No.36,2023 Compulsory Product Certification Catalogue Description and Scope Definition Table (2023 Revision)



国家市场监督管理总局-公众留言

查看留言
我要留言
我的留言

<ul style="list-style-type: none"> 食品安全协调 食品生产监管 食品销售 餐饮服务 食用农产品市 场销售监管 保健 特殊医学用途配方和婴幼儿 配方乳粉监管 食品监督抽检 召回 食品安全标准 特种设备人员 机构管理 特种设备检验 计量机构和人员管理 认证监督管理 认可与检验检测 	<p>组决议), 从企业角度, 别人都做, 我不做, 担心后续监管出问题。从认证机构来说, 一般是宁做过不错过, 让企业改下说明书, 就说也适用家用, 也给做了。 个人觉得上述做法欠妥, 还请领导澄清。</p>
<div style="display: flex; align-items: center; margin-bottom: 5px;">  <div style="margin-left: 5px;"> <p style="font-size: 0.9em;">按照GB 4706.13设计生产的电冰箱产品应属于强制性产品认证范围。强制性产品认证目录不包括不包括商用售卖机、散开式冷藏/冷冻展示柜、以独立形式存在的制冰机和冰淇淋机等产品。</p> </div> </div>	<p>回复部门: 认证监督管理局 时间: 2020-04-08</p>
<div style="display: flex; align-items: center; margin-bottom: 5px;">  <div style="margin-left: 5px;"> <p style="font-size: 0.8em; margin: 0;">梅飞强</p> </div> </div>	<p>工业类机房控制柜用空调器是否需要强制性认证 留言日期: 2018-12-25</p> <p>现有一款专供工业机房控制柜降温用的一体式单制冷空调器, 希望领导确认, 是否需要进行强制性认证</p>
<div style="display: flex; align-items: center; margin-bottom: 5px;">  <div style="margin-left: 5px;"> <p style="font-size: 0.9em;">专为工业用途设计的空调器产品不属于强制性产品认证范围。</p> </div> </div>	<p>回复部门: 认证监督管理局 时间: 2018-12-29</p>